Technical Specification





GROUND PADS

GROUNDING STUDS

CT MOUNTING BRACKETS





VERSAPACK VT ASSEMBLY PROVIDED BY DVP

PART #: DVPPCT33

DWG. TITLE:
3000 AMP PAD MOUNTED CT CABINET

DWG. NO.:
S240226

MATERIAL:
12 GAUGE GALVANNEALED SHEET STEEL

FINISH:
POWDER COAT ANSI 61 GRAY

NOTICE:
THIS INFORMATION IS THE PROPERTY OF N.J. SULLIVAN CO., ANY REPRODUCTION, PUBLICATION OR DISTRIBUTION TO A THIRD PARTY IS STRICTLY FORBIDDEN UNLESS WRITTEN PERMISSIONS ARE GIVEN BY AN AUTHORIZED AGENT OF:
N.J. SULLIVAN CO., INC.

DFTG.:	Adam Martin	DATE:	210824
CHKR.:		DATE:	
REV.:	Adam Martin	DATE:	240411
REV.:	Adam Martin	DATE:	240718
REV.:		DATE:	

N.J. SULLIVAN Co.
INCORPORATED
P.O. BOX 438, STERLING, VIRGINIA 20167
METAL FABRICATION
Phone: (703)-464-5944 Fax: (703)-464-5992
www.njsullivan.com

Technical Specification





SECTION A-A





LINK BAR

PART #: DVPPCT33

DWG. TITLE:	3000 AMP PAD MOUNTED CT CABINET
DWG. NO.:	S240226
MATERIAL:	12 GAUGE GALVANNEALED SHEET STEEL
FINISH:	POWDER COAT ANSI 61 GRAY

NOTICE:
THIS INFORMATION IS THE PROPERTY OF N.J. SULLIVAN CO., ANY REPRODUCTION, PUBLICATION OR DISTRIBUTION TO A THIRD PARTY IS STRICTLY FORBIDDEN UNLESS WRITTEN PERMISSIONS ARE GIVEN BY AN AUTHORIZED AGENT OF:
N.J. SULLIVAN CO., INC.

DFTG.:	Adam Martin	DATE:	210824
CHKR.:		DATE:	
REV.:	Adam Martin	DATE:	240411
REV.:	Adam Martin	DATE:	240718
REV.:		DATE:	

N.J. SULLIVAN CO.
INCORPORATED
P.O. BOX 438, STERLING, VIRGINIA 20167
METAL FABRICATION
Phone: (703)-464-5944 Fax: (703)-464-5992
www.njsullivan.com

Technical Specification



- CT cabinets are constructed with all welded seams. Material is 12 gauge galvannealed sheet steel, conforming with ASTM A653. Finish is powder coated ansi 61 gray.
- Double doors provided with continuous stainless steel piano hinges. 3 point latching mechanism supplied with padlockable vault handle. Bottom is open with a 1.5" internal flange with $\frac{5}{8}$" holes for mounting.
- Busbars are fabricated from silver plated copper bar stock, (3) $\frac{1}{4}$" x 4". Busbars are punched to accommodate standard 2 hole high-press lugs. Fiberglasss angles are provided for mounting CTs. 4 grounding studs (Burndy #GSC752N30B54) provided
- CT cabinets are constructed in accordance with UL bulletin #50 and NEMA 3R specifications.
- Cabinet weight is approximately 1080 lbs.

PART #: DVPPCT33

DWG. TITLE:
3000 AMP PAD MOUNTED CT CABINET

DWG. NO.: S240226

MATERIAL:
12 GAUGE GALVANNEALED SHEET STEEL

FINISH: POWDER COAT ANSI 61 GRAY

NOTICE:
THIS INFORMATION IS THE PROPERTY OF N.J. SULLIVAN CO., ANY REPRODUCTION, PUBLICATION OR DISTRIBUTION TO A THIRD PARTY IS STRICTLY FORBIDDEN UNLESS WRITTEN PERMISSIONS ARE GIVEN BY AN AUTHORIZED AGENT OF:
N.J. SULLIVAN CO., INC.

DFTG.:	Adam Martin	DATE:	210824
CHKR.:		DATE:	
REV.:	Adam Martin	DATE:	240411
REV.:	Adam Martin	DATE:	240718
REV.:		DATE:	

N.J. SULLIVAN CO.
INCORPORATED
P.O. BOX 438, STERLING, VIRGINIA 20167
METAL FABRICATION
Phone: (703)-464-5944 Fax: (703)-464-5992
www.njsullivan.com

Technical Specification



PART #: DVPPCT33

DWG. TITLE:	3000 AMP PAD MOUNTED CT CABINET
DWG. NO.:	S240226
MATERIAL:	12 GAUGE GALVANNEALED SHEET STEEL
FINISH:	POWDER COAT ANSI 61 GRAY

NOTICE:
THIS INFORMATION IS THE PROPERTY OF N.J. SULLIVAN CO., ANY REPRODUCTION, PUBLICATION OR DISTRIBUTION TO A THIRD PARTY IS STRICTLY FORBIDDEN UNLESS WRITTEN PERMISSIONS ARE GIVEN BY AN AUTHORIZED AGENT OF:
N.J. SULLIVAN CO., INC.

DFTG.:	Adam Martin	DATE:	210824
CHKR.:		DATE:	
REV.:	Adam Martin	DATE:	240411
REV.:	Adam Martin	DATE:	240718
REV.:		DATE:	

N.J. SULLIVAN Co.
INCORPORATED
P.O. BOX 438, STERLING, VIRGINIA 20167
METAL FABRICATION
Phone: (703)-464-5944 Fax: (703)-464-5992
www.njsullivan.com