NOTES:

1- NEMA 1 C/T cabinets are constructed with all welded seams. Material is 14ga. galvannealed sheet steel, conforming with ASTM A-653 & G60-U.

2- All interior and exterior surfaces are furnished primed.

3- Busbars are fabricated from aluminum alloy bar stock, 1/4" thick, 6061-T61 in accordance with ASTM B317. Minumum electrical conductivity at 20°C % IACS is 57%.

4- Busbar mounting channels are fabricated from structural reinforced fiber glass, crack resistant, flame retardant, electrically resistant, UL recognized.

5- All hardware used for assembly is plated steel.

6- Alternate configurations of cabinet, channels and busbars can be furnished upon request.

7- Shutter plates are furnished with cabinet.

8- C/T cabinet will be furnished with the following label:



MANUFACTURED BY
N.J. SULLIVAN CO.
INC.
STERLING, VA.

CAT. NO.		AMPS	
VOLTS		POLE	
SER. NO.		WIRE	

SUITABLE FOR USE AS SERVICE EQUIPMENT

DWG. TITLE:	PEPCO Metering CT Cabinet 400-800 Amp, 1 & 3 Phase, Nema 1
DWG. NO: PHICT81-1	PART NO: PHICT81
MATERIAL:	ASTM A653 Galvannealed
FINISH:	Galvannealed - ANSI 61

NOTICE:
THIS INFORMATION IS THE PROPERTY OF N.J. SULLIVAN CO., ANY REPRODUCTION, PUBLICATION OR DISTRIBUTION TO A THIRD PARTY IS STRICTLY FORBIDDEN UNLESS WRITTEN PERMISSIONS ARE GIVEN BY AN AUTHORIZED AGENT OF:
N.J. SULLIVAN CO., INC.

DFTG.:	CD	DATE:	8/16/11
CHKR.:		DATE:	
REV.:		DATE:	
REV.:		DATE:	
REV.:		DATE:	

N.J. SULLIVAN Co.
INCORPORATED
P.O. BOX 438, STERLING, VIRGINIA 20167
METAL FABRICATION
Phone: (703)-464-5944 Fax: (703)-464-5992
www.njsullivan.com



DWG. TITLE:	PEPCO Metering CT Cabinet 400-800 Amp, 1 & 3 Phase, Nema 1
DWG. NO:	PHICT81-2
PART NO:	PHICT81
MATERIAL:	ASTM A653 Galvannealed
FINISH:	Galvannealed - ANSI 61

NOTICE:
THIS INFORMATION IS THE PROPERTY OF N.J. SULLIVAN CO., ANY REPRODUCTION, PUBLICATION OR DISTRIBUTION TO A THIRD PARTY IS STRICTLY FORBIDDEN UNLESS WRITTEN PERMISSIONS ARE GIVEN BY AN AUTHORIZED AGENT OF:
N.J. SULLIVAN CO., INC.

DFTG.:	CD	DATE:	8/16/11
CHKR.:		DATE:	
REV.:		DATE:	
REV.:		DATE:	
REV.:		DATE:	

N.J. SULLIVAN Co.
INCORPORATED
P.O. BOX 438, STERLING, VIRGINIA 20167
METAL FABRICATION
Phone: (703)-464-5944 Fax: (703)-464-5992
www.njsullivan.com



DWG. TITLE:	PEPCO Metering CT Cabinet 400-800 Amp, 1 & 3 Phase, Nema 1
DWG. NO:	PHICT81-3
PART NO:	PHICT81
MATERIAL:	ASTM A653 Galvannealed
FINISH:	Galvannealed - ANSI 61

NOTICE:
THIS INFORMATION IS THE PROPERTY OF N.J. SULLIVAN CO., ANY REPRODUCTION, PUBLICATION OR DISTRIBUTION TO A THIRD PARTY IS STRICTLY FORBIDDEN UNLESS WRITTEN PERMISSIONS ARE GIVEN BY AN AUTHORIZED AGENT OF:
N.J. SULLIVAN CO., INC.

DFTG.:	CD	DATE:	8/16/11
CHKR.:		DATE:	
REV.:		DATE:	
REV.:		DATE:	
REV.:		DATE:	

N.J. SULLIVAN Co.
INCORPORATED
P.O. BOX 438, STERLING, VIRGINIA 20167
METAL FABRICATION
Phone: (703)-464-5944 Fax: (703)-464-5992
www.njsullivan.com