Technical Specification



RIGHT SIDE



FRONT

- CT cabinets are constructed with all welded seams. Material is 12 gauge galvanized sheet steel conforming with ASTM A-924 and G90.
- Cabinets are provided with front screw cover doors top and bottom with provisions for padlockable meter seals with ⅜"Ø holes. Middle cover hinged with screws and padlockable meter seals.
- Bottom is open with 1½" internal flange. ⅝"Ø holes are provided for mounting.
- (7) ¼" X 6" aluminum bus bars per phase top and bottom. (6) ¼" X 4" copper bus pars per phase used in mid-section to accommodate metering devices.
- CT cabinets are constructed in accordance with UL bulletin #50 and NEMA 3R specifications.

PART # DECT6KP3R

DWG. TITLE:	6000A DOMINION ENERGY CT CABINET
DWG. NO.:	S250325-1
MATERIAL:	12 GAUGE GALVANNEALED STEEL
FINISH:	POWDER COATED ANSI 61 GRAY

NOTICE:
THIS INFORMATION IS THE PROPERTY OF N.J. SULLIVAN CO., ANY REPRODUCTION, PUBLICATION OR DISTRIBUTION TO A THIRD PARTY IS STRICTLY FORBIDDEN UNLESS WRITTEN PERMISSIONS ARE GIVEN BY AN AUTHORIZED AGENT OF:
N.J. SULLIVAN CO., INC.

DFTG.:	Adam Martin	DATE: 3/25/2025
CHKR.:		DATE:
REV.:		DATE:
REV.:		DATE:
REV.:		DATE:

N.J. SULLIVAN Co.
INCORPORATED
P.O. BOX 438, STERLING, VIRGINIA 20167
METAL FABRICATION
Phone: (703)-464-5944 Fax: (703)-464-5992
www.njsullivan.com

Technical Specification



- Ampacity rating: copper; 1000 amps/sq in., aluminum; 750 amps/sq in.
- Load and line landing pads are ¼" x 6" aluminum bus (7x). Line side can accommodate (18) Hy-Press lugs, load side (18) Hy-Press lugs.
- Thru bars are composed of ¼" x 4" copper bus (6x) to accommodate doughnut type CTs.
- Neutral bars are composed of ¼" x 6" aluminum bus (7x).
- Ground bar is composed of ¼" x 6" aluminum bus (2x).
- All hardware grade 5 ½"-13 bolt, with plated steel nut, flat, and lock washers.

PART # DECT6KP3R

DWG. TITLE:	6000A DOMINION ENERGY CT CABINET
DWG. NO.:	S250325-2
MATERIAL:	12 GAUGE GALVANNEALED STEEL
FINISH:	POWDER COATED ANSI 61 GRAY

NOTICE:
THIS INFORMATION IS THE PROPERTY OF N.J. SULLIVAN CO., ANY REPRODUCTION, PUBLICATION OR DISTRIBUTION TO A THIRD PARTY IS STRICTLY FORBIDDEN UNLESS WRITTEN PERMISSIONS ARE GIVEN BY AN AUTHORIZED AGENT OF:
N.J. SULLIVAN CO., INC.

DFTG.:	Adam Martin	DATE: 3/25/2025
CHKR.:		DATE:
REV.:		DATE:
REV.:		DATE:
REV.:		DATE:

N.J. SULLIVAN Co.
INCORPORATED
P.O. BOX 438, STERLING, VIRGINIA 20167
METAL FABRICATION
Phone: (703)-464-5944 Fax: (703)-464-5992
www.njsullivan.com

Technical Specification







PART # DECT6KP3R

DWG. TITLE:	6000A DOMINION ENERGY CT CABINET
DWG. NO.:	S250325-3
MATERIAL:	12 GAUGE GALVANNEALED STEEL
FINISH:	POWDER COATED ANSI 61 GRAY

NOTICE:
THIS INFORMATION IS THE PROPERTY OF N.J. SULLIVAN CO., ANY REPRODUCTION, PUBLICATION OR DISTRIBUTION TO A THIRD PARTY IS STRICTLY FORBIDDEN UNLESS WRITTEN PERMISSIONS ARE GIVEN BY AN AUTHORIZED AGENT OF:
N.J. SULLIVAN CO., INC.

DFTG.:	Adam Martin	DATE: 3/25/2025
CHKR.:		DATE:
REV.:		DATE:
REV.:		DATE:
REV.:		DATE:

N.J. SULLIVAN Co.
INCORPORATED
P.O. BOX 438, STERLING, VIRGINIA 20167
METAL FABRICATION
Phone: (703)-464-5944 Fax: (703)-464-5992
www.njsullivan.com